

Test Verification of Conformity

Verification Number: 230501359SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the regulation(s) listed on this verification at the time the tests were carried out. Other standards and Regulations may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant **UK CA** mark regulations are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Danson Electrical UK Limited. Unit 30 and 31, Mount Pleasant Industrial Park, Northam, Southampton, SO14 OSP, United Kingdom
Manufacturing site Name&Address:	Zhejiang Leitai Electric Co.,Ltd 17# Zhenmin Road, Sibanqiao industrial zone, Liushi town, Wenzhou City, Zhejiang Province, China.
Product Description:	Surge Protective Device
Ratings & Principle Characteristics:	Type II, Uc: 275V~(L-N), 255V~(N-PE), In: 20kA, I _{max} : 40kA, Up: 1,5kV(L- N),1,3kV(N-PE), I _{scrr} : 25kA, IP20, used in TN/TT system, partially accessible, with mechanical internal disconnecter (show green for normal, show red for replacing), should be used together with 100A gL/gG external fuse for both L and N circuit.
Models/Type References:	DSCY251N2R
Brand Name(s):	DANSON
Standard(s)/Directive(s):	Electrical Equipment (Safety) Regulations 2016 BS EN 61643-11:2012+A11:2018
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2023-05-18 to 2023-06-27
Test Report Number(s):	230501358HA-001

Additional information in Appendix.



Signature

Name: Oliver Wei

Position: Manager

Date: 05 July 2023

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.